

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
Administration	Women's Rest Room By Room 103	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Administration	Room 303	Closet Floor Elongated Sloan-Zurn	5	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	5	1.3
Administration	Room 317	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Administration	Room 220	Closet Floor Elongated Sloan-Zurn	4	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	4	1.3
Administration	Room 225	Closet Floor Elongated Sloan-Zurn	6	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	6	1.3
Administration	Men's Rest Room By Room 101	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
Administration	Women's Rest Room By Room 103	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
Administration	Room 303	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
Administration	Room 317	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
Administration	Room 220	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
Administration	Room 225	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
Administration	Men's Rest Room By Room 101	Urinal Wall Round Sloan-Zurn	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Administration	Room 317	Urinal Wall Round Sloan-Zurn	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Administration	Room 317	Urinal Wall Elongated Sloan-Zurn	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Administration	Room 220	Urinal Wall Round Sloan-Zurn	3	1.5	Retrofit existing valve with 1.0 gpf kit	3	1.0
Administration	Men's Rest Room By Room 101	Lavatory Sink 4" Standard	1	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Administration	Women's Rest Room By Room 103	Lavatory Sink 4" Standard ADA	2	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Administration	Room 303	Lavatory Sink/Goose Neck 4" Standard ADA	1	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Administration	Room 303	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Administration	Room 317	Lavatory Sink/Goose Neck 4" Standard ADA	1	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Administration	Room 317	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Administration	Room 220	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Administration	Room 225	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Administration	Room 302	Kitchen Sink/Goose Neck 4" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Administration	Room 314	Kitchen Sink/Goose Neck 4" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Administration	Room 213	Kitchen Sink/Goose Neck 4" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Administration	Room 209	Kitchen Sink/Goose Neck 4" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Administration	Room 203	Kitchen Sink/Goose Neck 4" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Administration	Room 202	Kitchen Sink/Goose Neck 4" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Administration	Room 202	Lavatory Sink Single Faucet/Can't Moderate Standard	2	2.5	Single basin faucet with lever handel moderated to .5 gpm	2	0.5
Agricultural Mech	Women's Rest Room Room 104	Closet Floor Elongated Piston	1	3.5	New floor mounted elongated bowl and new 1.28 gpf sloan valve	1	1.3
Agricultural Mech	Men's Rest Room Room 106	Closet Floor Elongated Piston/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Agricultural Mech	Women's Rest Room Room 104	Lavatory Sink 4" Single Handle	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Agricultural Mech	Men's Rest Room Room 106	Lavatory Sink 4" Single Handle	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Art Annex	Unisex Rest Room	Closet Floor Rear Spud Sloan-Zurn/Convert To Top Spud	1	3.5	New Floor mounted elongated bowl and new 1.28 gpf valve and hardware to raise valve	1	1.3
Art Annex	Unisex Rest Room	Lavatory Sink 4" Single Handle	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Art Annex	Class Rooms	Kitchen Sink 8" Standard	3	2.2	Retrofit with 1.5 gpm VP laminar flow moderator	3	1.5

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/ unit
Art Center Gallery	Room 128	Closet Floor Elongated Sloan-Piston	1	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	1	1.3
Art Center Gallery	Room 126	Closet Floor Elongated Sloan-Piston	1	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	1	1.3
Art Center Gallery	Room 108	Closet Floor Elongated Sloan-Piston	2	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	2	1.3
Art Center Gallery	Room 106	Closet Floor Elongated Sloan-Piston	3	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	3	1.3
Art Center Gallery	Room 108	Closet Floor Elongated Pre 71/Need To Raise Valve ADA	1	4.0	New Floor mounted elongated bowl and new 1.28 gpf valve and hardware to raise valve	1	1.3
Art Center Gallery	Room 106	Closet Floor Elongated Pre 71/Need To Raise Valve ADA	1	4.0	New Floor mounted elongated bowl and new 1.28 gpf valve and hardware to raise valve	1	1.3
Art Center Gallery	Room 122	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Art Center Gallery	Room 131	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Art Center Gallery	Room 125	Closet Floor/Primary Elongated Sloan-Piston	3	4.0	New floor mounted primary bowl and new 1.6 gpf valve	3	1.6
Art Center Gallery	Room 108	Urinal Floor Round Sloan-Piston	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Art Center Gallery	Room 128	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Art Center Gallery	Room 125	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Art Center Gallery	Room 120	Lavatory Sink 4" Standard	1	2.8	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Art Center Gallery	Room 126	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Art Center Gallery	Room 122	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Art Center Gallery	Room 131	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Art Center Gallery	Room 108	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Art Center Gallery	Room 106	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Art Center Gallery	Room 109	Kitchen Sink Single Hole Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Art Center Gallery	Room 125	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Aviation Technology	Women's Rest Room Room 104	Closet Floor Elongated Tank/12" Setback ADA	1	3.5	New 1.0 gpf pressure assisted tank toilet with elongated bowl 12" Set Back - ADA	1	1.0
Aviation Technology	Men's Rest Room Room 106	Closet Floor Elongated Piston/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Aviation Technology	Men's Rest Room Room 106	Closet Floor Elongated Piston/Need To Raise Valve	1	3.5	New Floor mounted elongated bowl and new 1.28 gpf valve and hardware to raise valve	1	1.3
Aviation Technology	Men's Rest Room Room 106	Lavatory Sink 4" Single Handle	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Aviation Technology	Women's Rest Room Room 104	Lavatory Sink 4" Single Handle	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Dockery	Room 102	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Dockery	Room 308	Closet Floor Elongated Sloan-Zurn	2	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	2	1.3
Dockery	Room 306	Closet Floor Elongated Sloan-Zurn	2	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	2	1.3
Dockery	Room 106	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Dockery	Room 206	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Dockery	Room 204	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Dockery	Room 308	Urinal Floor Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Dockery	Room 206	Urinal Wall Round Sloan-Zurn	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Dockery	Room 106	Urinal Floor Round Sloan-Zurn	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
Dockery	Room 308	Lavatory Sink 8" Standard	2	2.8	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Dockery	Room 306	Lavatory Sink 8" Standard	2	2.8	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Dockery	Room 206	Lavatory Sink 8" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Dockery	Room 204	Lavatory Sink 8" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Dockery	Room 106	Lavatory Sink 8" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Dockery	Room 106	Lavatory Sink/Goose Neck 8" Standard ADA	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Dockery	Room 102	Lavatory Sink 8" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Gaines	Room 311	Closet Wall Elongated Sloan-Zurn	2	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	2	1.3
Gaines	Room 309	Closet Wall Elongated Sloan-Zurn	3	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	3	1.3
Gaines	Room 211	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Gaines	Room 209	Closet Wall Elongated Sloan-Zurn	2	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	2	1.3
Gaines	Room 105	Closet Wall Elongated Sloan-Zurn	2	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	2	1.3
Gaines	Room 107	Closet Wall Elongated Sloan-Zurn	2	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	2	1.3
Gaines	Room 311	Urinal Wall Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Gaines	Room 211	Urinal Wall Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Gaines	Room 105	Urinal Wall Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Gaines	Room 311	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Gaines	Room 309	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Gaines	Room 211	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Gaines	Room 209	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Gaines	Room 105	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Gaines	Room 107	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
General Services	Craft and Trades Women's Rest Room	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor/27" VB Tube ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - 27" VB Tube ADA	1	1.3
General Services	Purchasing and Printing Men's Rest Room	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
General Services	Purchasing and Printing Women's Rest Room	Closet Floor Elongated Sloan-Zurn	2	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	2	1.3
General Services	Physical Plant Men's Rest Room	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
General Services	Physical Plant Women's Rest Room	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
General Services	Projects Women's Rest Room	Closet Floor Round Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
General Services	Projects Men's Rest Room	Closet Floor Round Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
General Services	Locker Room	Closet Floor Elongated Sloan-Zurn	3	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	3	1.3
General Services	Craft and Trades Men's Rest Room	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
General Services	Craft and Trades Women's Rest Room	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
General Services	Purchasing and Printing Men's Rest Room	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
General Services	Purchasing and Printing Women's Rest Room	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
General Services	Physical Plant Men's Rest Room	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
General Services	Physical Plant Women's Rest Room	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
General Services	Craft and Trades Men's Rest Room	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
General Services	Purchasing and Printing Men's Rest Room	Urinal Wall Round Sloan	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
General Services	Projects Men's Rest Room	Urinal Wall Round Sloan	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
General Services	Purchasing and Printing Men's Rest Room	Lavatory Sink 4" Single Handle	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
General Services	Purchasing and Printing Men's Rest Room	Lavatory Sink 4" Gooseneck	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
General Services	Purchasing and Printing Women's Rest Room	Lavatory Sink 4" Single Handle	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
General Services	Purchasing and Printing Women's Rest Room	Lavatory Sink 4" Gooseneck	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
General Services	Purchasing by Garage Door Rest Room	Lavatory Sink 4" Single Handle	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
General Services	Physical Plant Men's Rest Room	Lavatory Sink 4" Single Handle	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
General Services	Physical Plant Women's Rest Room	Lavatory Sink 4" Single Handle	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
General Services	Projects Women's Rest Room	Lavatory Sink 4" Single Handle	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
General Services	Projects Men's Rest Room	Lavatory Sink 4" Single Handle	2	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
General Services	Locker Room	Lavatory Sink Face Mount Twist	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
General Services	Craft and Trades Women's Rest Room	Lavatory Sink 4" Single Handle	2	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
General Services	Kitchen Area	Kitchen Sink 8" Single Handle	1	2.2	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Grinstead	Room 306	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Grinstead	Room 319	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Grinstead	Room 123	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Grinstead	Room 114	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Grinstead	Room 306	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Grinstead	Room 319	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Grinstead	Room 237	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor	3	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	3	1.3
Grinstead	Room 230	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor	4	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	4	1.3
Grinstead	Room 202	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Grinstead	Room 102	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Grinstead	Room 123	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor	2	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	2	1.3
Grinstead	Room 114	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Grinstead	Room 009E	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Grinstead	Room 18	Closet Floor Elongated Sloan-Zurn/Side Mount Sensor	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Grinstead	Room 202	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
Grinstead	Room 200	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
Grinstead	Room 102	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
Grinstead	Room 100	Closet Floor Elongated Sloan-Zurn ADA	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf - ADA	1	1.3
Grinstead	Room 306	Urinal Floor Round Sloan-Zurn/Side Mount Sensor	4	1.5	Retrofit existing valve with 1.0 gpf kit	4	1.0
Grinstead	Room 200	Urinal Floor Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Grinstead	Room 100	Urinal Floor Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Grinstead	Room 114	Urinal Floor Round Sloan-Zurn	5	1.5	Retrofit existing valve with 1.0 gpf kit	5	1.0
Grinstead	Room 306	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Grinstead	Room 319	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Grinstead	Room 237	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Grinstead	Room 230	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Grinstead	Room 202	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Grinstead	Room 200	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Grinstead	Room 102	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Grinstead	Room 100	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Grinstead	Room 107	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Grinstead	Room 123	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Grinstead	Room 114	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Grinstead	Room 009E	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Grinstead	Room 16	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Grinstead	Room 18	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Grinstead	Room 240	Kitchen Sink 8" Standard	6	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	6	1.5
Grinstead	Room 246	Kitchen Sink 8" Standard	8	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	8	1.5
Grinstead	Room 120C	Kitchen Sink/Goose Neck 4" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Grinstead	Room 119	Kitchen Sink/Goose Neck 8" Standard	2	2.0	Retrofit with 1.5 gpm VP laminar flow moderator	2	1.5
Grinstead	Room 128	Kitchen Sink 8" Standard	2	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	2	1.5
Grinstead	Room 115	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Health Center	Room 216D Unisex Rest Room	Closet Floor Elongated Tank/12" Setback ADA	1	3.5	New 1.0 gpf pressure assisted tank toilet with elongated bowl 12" Set Back - ADA	1	1.0
Health Center	Throughout the Building General Rest Room's	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve	9	3.5	New Floor mounted elongated bowl and new 1.28 gpf valve and hardware to raise valve	9	1.3
Health Center	Lobby Men's Rest Room	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Health Center	Lobby Women's Rest Room	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Health Center	Unisex Rest Room 214 A	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Health Center	Lobby Men's Rest Room	Lavatory Sink 4" Single Handle	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Health Center	Lobby Women's Rest Room	Lavatory Sink 4" Single Handle	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Health Center	Room 216D Unisex Rest Room	Lavatory Sink 4" Single Handle	1	1.7	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Health Center	Unisex Rest Room 214 A	Lavatory Sink 4" Single Handle	1	1.7	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Health Center	Throughout the Building General Rest Room's	Lavatory Sink 4" Single Handle	9	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	9	0.5
Health Center	Room 214	Kitchen Sink 8" Standard	2	2.0	Retrofit with 1.5 gpm VP laminar flow moderator	2	1.5
Health Center	Exam Room	Lavatory Sink 8" Gooseneck ADA	8	2.0	Retrofit with 1.5 gpm VP laminar flow moderator	8	1.5
Hendricks Hall	Room 207C	Closet Floor Elongated Tank/12" Setback	1	5.0	New 1.0 gpf pressure assisted tank toilet with elongated bowl 12" Set Back	1	1.0
Hendricks Hall	Room 207B	Lavatory Sink 4" Standard	1	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Hendricks Hall	Room 207C	Lavatory Sink 4" Standard	1	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Highlander Theater	Room 204A	Shower Head Plastic Standard	2	2.5	New Plastic Showerhead 2.0 gpm	2	2.0
Highlander Theater	Room 204B	Shower Head Plastic Standard	2	2.5	New Plastic Showerhead 2.0 gpm	2	2.0

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
Highlander Theater	Room 204B	Urinal Wall Round Sloan-Piston	1	1.5	New Sloan valve 1.0 gpf	1	1.0
Highlander Theater	Room 102	Urinal Wall Round Sloan-Piston	2	1.5	New Sloan valve 1.0 gpf	2	1.0
Highlander Theater	Room 103	Closet Wall Elongated Sloan-Piston	1	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	1	1.3
Highlander Theater	Room 204A	Closet Wall Elongated Sloan-Piston	3	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	3	1.3
Highlander Theater	Room 204B	Closet Wall Elongated Sloan-Piston	1	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	1	1.3
Highlander Theater	Room 102	Closet Wall Elongated Sloan-Piston	2	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	2	1.3
Highlander Theater	Room 101	Closet Wall Elongated Sloan-Piston	4	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	4	1.3
Highlander Theater	Room 103	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Highlander Theater	Room 204A	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Highlander Theater	Room 204B	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Highlander Theater	Room 102	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Highlander Theater	Room 101	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Highway Safety Center	Women's Rest Room	Closet Floor Elongated Tank/12" Setback ADA	1	3.5	New 1.0 gpf pressure assisted tank toilet with elongated bowl 12" Set Back - ADA	1	1.0
Highway Safety Center	Women's Rest Room	Closet Floor Elongated Tank/12" Setback ADA	1	3.5	New 1.0 gpf pressure assisted tank toilet with elongated bowl 12" Set Back - ADA	1	1.0
Highway Safety Center	Men's Rest Room	Closet Floor Elongated Tank/12" Setback ADA	1	3.5	New 1.0 gpf pressure assisted tank toilet with elongated bowl 12" Set Back - ADA	1	1.0
Highway Safety Center	Women's Rest Room	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Highway Safety Center	Men's Rest Room	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Highway Safety Center	Break Room	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Humphreys	Room 321	Urinal Wall Round Sloan-Zurn	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Humphreys	Room 219	Urinal Wall Round Sloan-Zurn	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Humphreys	Room 123M	Urinal Wall Round Sloan-Zurn	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Humphreys	Room 319	Lavatory Sink 4" Standard	2	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Humphreys	Room 321	Lavatory Sink 4" Standard	2	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Humphreys	Room 219	Lavatory Sink 4" Standard	2	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Humphreys	Room 217	Lavatory Sink 4" Standard	2	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Humphreys	Room 121W	Lavatory Sink 4" Standard	2	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Humphreys	Room 123M	Lavatory Sink 4" Standard	2	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Kirkpatrick Library	1st Floor Men's Rest Room	Closet Wall Elongated Sloan-Zurn	2	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	2	1.3
Kirkpatrick Library	1st Floor Men's Rest Room #2	Closet Wall Elongated Sloan-Zurn	2	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	2	1.3
Kirkpatrick Library	1st Floor Women's Rest Room #2	Closet Wall Elongated Sloan-Zurn	3	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	3	1.3
Kirkpatrick Library	1st Floor Men's Rest Room	Urinal Wall Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Kirkpatrick Library	2nd Floor Men's Rest Room	Lavatory Sink 4" Sloan-Zurn	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Kirkpatrick Library	2nd Floor Men's Rest Room	Lavatory Sink/Goose Neck 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Kirkpatrick Library	2nd Floor Women's Rest Room	Lavatory Sink/Goose Neck 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Kirkpatrick Library	3rd Floor Women's Rest Room	Lavatory Sink/Goose Neck 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Kirkpatrick Library	3rd Floor Men's Rest Room	Lavatory Sink/Goose Neck 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Kirkpatrick Library	1st Floor Men's Rest Room	Lavatory Sink/Goose Neck 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Kirkpatrick Library	1st Floor Men's Rest Room	Lavatory Sink 4" Sloan-Zurn	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Kirkpatrick Library	1st Floor Women's Rest Room	Lavatory Sink/Goose Neck 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Kirkpatrick Library	1st Floor Men's Rest Room #2	Lavatory Sink/Goose Neck 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Kirkpatrick Library	1st Floor Women's Rest Room #2	Lavatory Sink/Goose Neck 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
Kirkpatrick Library	2nd Floor Men's Rest Room #2	Lavatory Sink/Goose Neck 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Kirkpatrick Library	2nd Floor Women's Rest Room #2	Lavatory Sink/Goose Neck 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Kirkpatrick Library	3rd Floor Men's Rest Room #2	Lavatory Sink/Goose Neck 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Kirkpatrick Library	3rd Floor Women's Rest Room #2	Lavatory Sink/Goose Neck 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Kirkpatrick Library	Room 2251	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Kirkpatrick Library	Room 1254	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Kirkpatrick Library	Room 1350	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Kirkpatrick Library	Room 1346	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Kirkpatrick Library	Room 1140	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Kirkpatrick Library	Room 1446	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Lovinger	Room 2000	Closet Floor Elongated Sloan-Piston	1	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	1	1.3
Lovinger	Room 2020	Closet Floor Elongated Sloan-Piston	2	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	2	1.3
Lovinger	Room 2000	Urinal Wall Round Sloan-Piston	1	1.5	New Sloan valve 1.0 gpf	1	1.0
Lovinger	Room 3290	Urinal Floor Round Sloan-Zurn	4	1.5	Retrofit existing valve with 1.0 gpf kit	4	1.0
Lovinger	Room 4270	Urinal Floor Round Sloan-Zurn	4	1.5	Retrofit existing valve with 1.0 gpf kit	4	1.0
Lovinger	Room 2230	Urinal Floor Round Sloan-Piston	4	1.5	Retrofit existing valve with 1.0 gpf kit	4	1.0
Lovinger	Room 1255	Urinal Floor Round Sloan-Piston	4	2.0	Retrofit existing valve with 1.0 gpf kit	4	1.0
Lovinger	Room 3290	Lavatory Sink 4" Standard	3	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Lovinger	Room 3280	Lavatory Sink 4" Standard	4	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Lovinger	Room 4270	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Lovinger	Room 4250	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Lovinger	Room 2000	Lavatory Sink 4" Standard	1	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Lovinger	Room 2020	Lavatory Sink 4" Standard	1	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Lovinger	Room 2210	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Lovinger	Room 2230	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Lovinger	Room 1255	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Martin	Room 69	Closet Floor Elongated Sloan-Piston	1	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	1	1.3
Martin	Room 65	Closet Floor Elongated Sloan-Piston	1	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	1	1.3
Martin	Room 120	Urinal Wall Round Sloan-Piston	1	1.5	New Sloan valve 1.0 gpf	1	1.0
Martin	Room 237	Urinal Wall Round Sloan-Piston	4	1.5	New Sloan valve 1.0 gpf	4	1.0
Martin	Room 337	Urinal Wall Round Sloan-Piston	4	1.5	New Sloan valve 1.0 gpf	4	1.0
Martin	Room 137	Urinal Wall Round Sloan-Piston	4	1.5	New Sloan valve 1.0 gpf	4	1.0
Martin	Room 69	Urinal Floor Round Sloan-Piston	4	1.5	New Sloan valve 1.0 gpf	4	1.0
Martin	Room 10	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Martin	Room 120	Closet Wall Elongated Sloan-Piston	1	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	1	1.3
Martin	Room 122	Closet Wall Elongated Sloan-Piston	2	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	2	1.3
Martin	Room 237	Closet Wall Elongated Sloan-Piston	3	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	3	1.3
Martin	Room 233	Closet Wall Elongated Sloan-Piston	5	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	5	1.3
Martin	Room 337	Closet Wall Elongated Sloan-Piston	3	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	3	1.3
Martin	Room 333	Closet Wall Elongated Sloan-Piston	5	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	5	1.3

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
Martin	Room 133	Closet Wall Elongated Sloan-Piston	5	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	5	1.3
Martin	Room 137	Closet Wall Elongated Sloan-Piston	3	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	3	1.3
Martin	Room 69	Closet Wall Elongated Sloan-Piston	2	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	2	1.3
Martin	Room 65	Closet Wall Elongated Sloan-Piston	4	4.0	New wall mounted elongated bowl with new 1.28 gpf valve	4	1.3
Martin	Room 120	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Martin	Room 122	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Martin	Room 237	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Martin	Room 233	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Martin	Room 337	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Martin	Room 333	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Martin	Room 133	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Martin	Room 137	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Martin	Room 69	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Martin	Room 65	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Martin	Room 10	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Martin	Room 12	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Martin	Room 234	Kitchen Sink/Goose Neck 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Martin	Room 334	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Morris Science	Room 225	Urinal Floor Round Sloan-Piston	5	1.5	New Sloan valve 1.0 gpf	5	1.0
Morris Science	Room 429	Urinal Floor Round Sloan-Piston	4	1.5	New Sloan valve 1.0 gpf	4	1.0
Morris Science	Room 325	Urinal Floor Round Sloan-Piston	5	1.5	New Sloan valve 1.0 gpf	5	1.0
Morris Science	Room 137	Urinal Floor Round Sloan-Piston	4	1.5	New Sloan valve 1.0 gpf	4	1.0
Morris Science	Room 223	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Morris Science	Room 225	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Morris Science	Room 429	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Morris Science	Room 4270	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Morris Science	Room 325	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Morris Science	Room 323	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Morris Science	Room 135	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Morris Science	Room 137	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Multipurpose	Men's Locker Room Room 115	Shower Head Plastic Hand Wand ADA	1	2.5	New Plastic Handheld Showerhead, 2.0 gpm	1	2.0
Multipurpose	Room 113	Shower Head Plastic Standard ADA	1	2.5	New Plastic Handheld Showerhead, 2.0 gpm	1	2.0
Multipurpose	Men's Locker Room Room 115	Shower Head Plastic Standard	8	2.5	New Plastic Showerhead 2.0 gpm	8	2.0
Multipurpose	Room 113	Shower Head Plastic Standard	6	2.5	New Plastic Showerhead 2.0 gpm	6	2.0
Multipurpose	Room 106	Shower Head Plastic Standard	3	2.5	New Plastic Showerhead 2.0 gpm	3	2.0
Multipurpose	Room 107	Shower Head Plastic Standard	3	2.5	New Plastic Showerhead 2.0 gpm	3	2.0
Multipurpose	Men's Rest Room Room 100B	Closet Wall Elongated Sloan-Zurn ADA	1	3.5	New wall mounted elongated ADA bowl retrofit existing valve to 1.28 gpf	1	1.3
Multipurpose	Men's Rest Room Room 100G	Closet Wall Elongated Sloan-Zurn	2	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	2	1.3
Multipurpose	Men's Rest Room Room 100B	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Multipurpose	Men's Rest Room Room 110	Closet Wall Elongated Sloan-Zurn	2	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	2	1.3
Multipurpose	Men's Locker Room Room 115	Closet Wall Elongated Sloan-Zurn	4	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	4	1.3
Multipurpose	Men's Rest Room Room 118	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
Multipurpose	Men's Rest Room Room 118	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Multipurpose	Men's Rest Room Room 214	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Multipurpose	Men's Rest Room Room 210	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Multipurpose	Room 113	Closet Wall Elongated Sloan-Zurn	3	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	3	1.3
Multipurpose	Room 106	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Multipurpose	Room 107	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Multipurpose	Room 211	Closet Wall Elongated Sloan-Zurn	5	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	5	1.3
Multipurpose	Room 213	Closet Wall Elongated Sloan-Zurn	5	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	5	1.3
Multipurpose	Room 109	Closet Wall Elongated Sloan-Zurn	3	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	3	1.3
Multipurpose	Room 119	Closet Wall Elongated Sloan-Zurn	3	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	3	1.3
Multipurpose	Room 100C	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Multipurpose	Room 100F	Closet Wall Elongated Sloan-Zurn	3	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	3	1.3
Multipurpose	Men's Rest Room Room 214	Closet Wall Elongated Sloan-Zurn/Need To Raise Valve	1	3.5	New Wall mounted elongated bowl with new 1.28 gpf valve and hardware to raise valve	1	1.3
Multipurpose	Men's Rest Room Room 210	Closet Wall Elongated Sloan-Zurn/Need To Raise Valve	1	3.5	New Wall mounted elongated bowl with new 1.28 gpf valve and hardware to raise valve	1	1.3
Multipurpose	Room 211	Closet Wall Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New Wall mounted elongated bowl with new 1.28 gpf valve and hardware to raise valve	1	1.3
Multipurpose	Room 213	Closet Wall Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New Wall mounted elongated bowl with new 1.28 gpf valve and hardware to raise valve	1	1.3
Multipurpose	Room 100C	Closet Wall Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New Wall mounted elongated bowl with new 1.28 gpf valve and hardware to raise valve	1	1.3
Multipurpose	Men's Rest Room Room 100G	Urinal Floor Round Sloan-Zurn	3	1.5	Retrofit existing valve with 1.0 gpf kit	3	1.0
Multipurpose	Men's Rest Room Room 100B	Urinal Floor Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Multipurpose	Men's Rest Room Room 110	Urinal Floor Round Sloan-Zurn	3	1.5	Retrofit existing valve with 1.0 gpf kit	3	1.0
Multipurpose	Men's Locker Room Room 115	Urinal Floor Round Sloan-Zurn	4	1.5	Retrofit existing valve with 1.0 gpf kit	4	1.0
Multipurpose	Men's Rest Room Room 118	Urinal Floor Round Sloan-Zurn	3	1.5	Retrofit existing valve with 1.0 gpf kit	3	1.0
Multipurpose	Men's Rest Room Room 100G	Lavatory Sink 4" Single Handle	3	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Multipurpose	Men's Rest Room Room 100B	Lavatory Sink 4" Single Handle	3	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Multipurpose	Men's Rest Room Room 110	Lavatory Sink 4" Standard	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Multipurpose	Men's Rest Room Room 110	Lavatory Sink 4" Single Handle	2	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Multipurpose	Men's Locker Room Room 115	Lavatory Sink 4" Single Handle	6	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	6	0.5
Multipurpose	Men's Rest Room Room 118	Lavatory Sink 4" Single Handle	3	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Multipurpose	Men's Rest Room Room 214	Lavatory Sink 4" Single Handle	5	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	5	0.5
Multipurpose	Men's Rest Room Room 210	Lavatory Sink 4" Single Handle	5	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	5	0.5
Multipurpose	Room 113	Lavatory Sink 4" Standard	4	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Multipurpose	Room 106	Lavatory Sink 4" Standard	2	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Multipurpose	Room 107	Lavatory Sink 4" Standard	2	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Multipurpose	Room 211	Lavatory Sink 4" Standard	6	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	6	0.5
Multipurpose	Room 213	Lavatory Sink 4" Standard	6	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	6	0.5

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
Multipurpose	Room 109	Lavatory Sink 4" Standard	3	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Multipurpose	Room 119	Lavatory Sink 4" Standard	3	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Multipurpose	Room 100C	Lavatory Sink 4" Standard	3	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Multipurpose	Room 100F	Lavatory Sink 4" Standard	3	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Multipurpose	Room 203	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
National Police	Room 106A	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
National Police	Room 106C	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
National Police	Room 106C	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve	1	3.5	New Floor mounted elongated bowl and new 1.28 gpf valve and hardware to raise valve	1	1.3
National Police	Room 102	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve	1	3.5	New Floor mounted elongated bowl and new 1.28 gpf valve and hardware to raise valve	1	1.3
National Police	Room 106A	Urinal Wall Round Pre 71	3	1.5	New Sloan valve 1.0 gpf	3	1.0
National Police	Room 106A	Lavatory Sink 4" Standard	2	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
National Police	Room 106C	Lavatory Sink 4" Standard	2	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
National Police	Room 102	Lavatory Sink 4" Standard	1	2.3	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
National Police	Kitchen	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Public Safety	Front Women's Rest Room	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Public Safety	Front Men's Rest Room	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Public Safety	Rear Women's Rest Room	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Public Safety	Rear Men's Rest Room	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Public Safety	Front Men's Rest Room	Urinal Wall Round Sloan	1	2.0	Retrofit existing valve with 1.0 gpf kit	1	1.0
Public Safety	Rear Men's Rest Room	Urinal Wall Round Sloan	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Public Safety	Front Women's Rest Room	Lavatory Sink 4" Standard	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Public Safety	Front Men's Rest Room	Lavatory Sink 4" Standard	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Public Safety	Locksmith Rest Room	Lavatory Sink 4" Single Handle	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Public Safety	Rear Women's Rest Room	Lavatory Sink 4" Standard	1	1.7	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Public Safety	Rear Men's Rest Room	Lavatory Sink 4" Standard	1	1.7	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Public Safety	Break Room	Kitchen Sink 8" Gooseneck	1	2.0	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
South Recreation Complex	Lobby Rest Room	Shower Head Plastic Standard	1	2.5	New Plastic Showerhead 2.0 gpm	1	2.0
South Recreation Complex	Women's Locker Room	Shower Head Plastic Standard	12	2.5	New Plastic Showerhead 2.0 gpm	12	2.0
South Recreation Complex	Men's Rest Room	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
South Recreation Complex	Women's Rest Room	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
South Recreation Complex	Lobby Rest Room	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
South Recreation Complex	Women's Locker Room	Lavatory Sink 4" Standard	10	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	10	0.5
South Recreation Complex	Lobby	Kitchen Sink 8" Standard	1	2.3	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5
Stahl Construction Technology	Suite Room 203	Closet Floor Round Tank/12" Setback	1	3.5	New 1.0 gpf pressure assisted tank toilet with elongated bowl 12" Set Back	1	1.0
Stahl Construction Technology	Men's Rest Room Room 110	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Stahl Construction Technology	Women's Rest Room Room 111	Closet Wall Elongated Sloan-Zurn	1	3.5	New wall mounted elongated bowl retrofit existing valve to 1.28 gpf	1	1.3
Stahl Construction Technology	Men's Rest Room Room 110	Urinal Wall Round Sloan	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Stahl Construction Technology	Men's Rest Room Room 110	Lavatory Sink 8" Standard	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Stahl Construction Technology	Women's Rest Room Room 111	Lavatory Sink 8" Standard	1	1.5	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Stahl Construction Technology	Suite Room 203	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Stahl Construction Technology	Suite Room 203	Kitchen Sink 4" Standard	1	2.2	Retrofit with 1.5 gpm VP laminar flow moderator	1	1.5

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/ unit
Utt	Room 103	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Utt	Room 105	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Utt	Room 207	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Utt	Room 3	Closet Floor Elongated Sloan-Zurn	2	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	2	1.3
Utt	Room 5	Closet Floor Elongated Sloan-Zurn	2	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	2	1.3
Utt	Room 248	Closet Floor/Wall Out/Angle Back Elongated Sloan-Zurn	1	3.5	New Floor mounted elongated wall outlet bowl with angle back and retrofit existing valve to 1.6 gpf	1	1.6
Utt	Room 207	Urinal Wall Round Sloan-Zurn	1	1.5	Retrofit existing valve with 1.0 gpf kit	1	1.0
Utt	Room 103	Urinal Wall Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Utt	Room 3	Urinal Floor Round Sloan-Zurn	2	1.5	Retrofit existing valve with 1.0 gpf kit	2	1.0
Utt	Room 207	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Utt	Room 248	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Utt	Room 103	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Utt	Room 105	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Utt	Room 3	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Utt	Room 5	Lavatory Sink 4" Standard	2	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Ward Edwards	1st Floor Men's Rest Room By Room 0506	Urinal Floor Round Sloan-Zurn	3	1.5	Retrofit existing valve with 1.0 gpf kit	3	1.0
Ward Edwards	3rd Floor Men's Rest Room	Lavatory Sink/Goose Neck 4" Standard ADA	2	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Ward Edwards	3rd Floor Women's Rest Room	Lavatory Sink/Goose Neck 4" Standard ADA	2	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Ward Edwards	3rd Floor Women's Rest Room By Room 3310	Lavatory Sink/Goose Neck 4" Standard ADA	4	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Ward Edwards	3rd Floor Men's Rest Room By Room 3310	Lavatory Sink/Goose Neck 4" Standard ADA	4	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Ward Edwards	3rd Floor Women's Rest Room By Room 3540	Lavatory Sink/Goose Neck 4" Standard ADA	4	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Ward Edwards	3rd Floor Men's Rest Room By Room 3540	Lavatory Sink/Goose Neck 4" Standard ADA	4	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Ward Edwards	2nd Floor Men's Rest Room By Room 2540	Lavatory Sink/Goose Neck 4" Standard ADA	4	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Ward Edwards	2nd Floor Women's Rest Room By Room 2540	Lavatory Sink/Goose Neck 4" Standard ADA	4	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Ward Edwards	2nd Floor Men's Rest Room By Room 2310	Lavatory Sink/Goose Neck 4" Standard ADA	4	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Ward Edwards	2nd Floor Women's Rest Room By Room 2310	Lavatory Sink/Goose Neck 4" Standard ADA	4	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Ward Edwards	2nd Floor Men's Rest Room	Lavatory Sink/Goose Neck 4" Standard ADA	2	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Ward Edwards	2nd Floor Women's Rest Room	Lavatory Sink/Goose Neck 4" Standard ADA	2	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Ward Edwards	1st Floor Men's Rest Room By Room 1530	Lavatory Sink/Goose Neck 4" Standard ADA	3	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Ward Edwards	1st Floor Women's Rest Room By Room 1530	Lavatory Sink/Goose Neck 4" Standard ADA	3	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Ward Edwards	1st Floor Men's Rest Room By Room 1704	Lavatory Sink/Goose Neck 4" Standard ADA	2	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Ward Edwards	1st Floor Women's Rest Room By Room 1704	Lavatory Sink/Goose Neck 4" Standard ADA	2	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	2	0.5
Ward Edwards	1st Floor Women's Rest Room By Room 1310	Lavatory Sink/Goose Neck 4" Standard ADA	3	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Ward Edwards	1st Floor Men's Rest Room By Room 1310	Lavatory Sink/Goose Neck 4" Standard ADA	3	2.5	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Ward Edwards	1st Floor Women's Rest Room By Room 0506	Lavatory Sink 4" Standard ADA	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Ward Edwards	1st Floor Women's Rest Room By Room 0506	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Ward Edwards	1st Floor Men's Rest Room By Room 0506	Lavatory Sink 4" Standard ADA	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5

Facility Name	Room	Existing Fixture Description	Existing Qty	Existing Usage	Measure Description	Qty Upgraded	New gal/unit
Ward Edwards	1st Floor Men's Rest Room By Room 0506	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Wood	Room 113	Closet Floor Elongated Sloan-Piston	1	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	1	1.3
Wood	Room 115	Closet Floor Elongated Sloan-Piston	1	4.0	New floor mounted elongated bowl and new 1.28 gpf sloan valve	1	1.3
Wood	Room 300C	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Wood	Room 300B	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Wood	Room 200C	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Wood	Room 200B	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Wood	Room 100C	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Wood	Room 100B	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Wood	Room 000C	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Wood	Room 000B	Closet Floor Elongated Sloan-Zurn/Need To Raise Valve ADA	1	3.5	New floor mounted elongated bowl and new 1.28 gpf valve - ADA, includes hardware to raise valve	1	1.3
Wood	Room 300C	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Wood	Room 300B	Closet Floor Elongated Sloan-Zurn	3	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	3	1.3
Wood	Room 200C	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Wood	Room 200B	Closet Floor Elongated Sloan-Zurn	3	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	3	1.3
Wood	Room 100C	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Wood	Room 100B	Closet Floor Elongated Sloan-Zurn	3	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	3	1.3
Wood	Room 000C	Closet Floor Elongated Sloan-Zurn	1	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	1	1.3
Wood	Room 000B	Closet Floor Elongated Sloan-Zurn	3	3.5	New floor mounted elongated bowl and retrofit existing valve to 1.28 gpf	3	1.3
Wood	Room 113	Urinal Wall Round Sloan-Zurn/Optima Sensor	1	1.5	Retrofit existing Optima valve with 1.0 gpf kit	1	1.0
Wood	Room 300C	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Wood	Room 300B	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Wood	Room 200C	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Wood	Room 200B	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Wood	Room 100C	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Wood	Room 100B	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Wood	Room 000C	Lavatory Sink 4" Standard	3	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	3	0.5
Wood	Room 000B	Lavatory Sink 4" Standard	4	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	4	0.5
Wood	Room 113	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5
Wood	Room 115	Lavatory Sink 4" Standard	1	2.0	Retrofit with 0.5 gpm vandal proof spray moderator	1	0.5